


# **LED Emergency Luminaries**








# LED Twin Spot Recess Mount Emergency Light

Surface / Recess MountModel: SLEL-05-A

Monthly Self-Test Function








SPECIFICATION	
	SLEL-05-A
	Recess
	Non-Maintained Type
	2 x 1W High Quality LED chips
	Powder-coated Mild Steel
	AC 180V–242V, 50Hz
	NiCd 3.6V 900mAh
	2W
	≤ 12 hours
	≥ 2 Hours
	IP20
	Class one Earthing
	0°C~50°C
	≥ 50000 Hours
ban	Approx. 4 year
	"Red" "Yellow" "Green" indication light & "Test" switch
	Press type
	"Red "LED Mains On, "Green" LED Charging, "Yellow" LED Fault

ed "LED Mains On, "Green" LED Charging "Yellow" LED Fault HKFSD Codes of Practice for minimum service installations and equipments \*FSD PPA 104(A) 4th Revision \*BSEN 60598-2-22:2008, \*BS 5266-1:2012



Web Site http:www.sl-led-application.com

## E-mail

info@sl-led-application.com

#### Tel

852 - 2370 9394

## Fax

852 - 2743 1123

#### Address

Unit 202A, 20/F., Tak King Industrial Building, 27 Cheung Lee Street, Chai Wan, Hong Kong.

#### Editor

Au Pui Man (openopw@gmail.com)