

LED Emergency Luminaries









LED Twin Spot Recess Mount Emergency Light

Surface / Recess Mount Model: SLEL-05

Monthly Self-Test Function



S	SPECIFICA
Model No.	
Installation Mode	
Luminaries Type	
Light Source	
Housing	
Input Voltage	
Rechargeable Battery	
Total Power Consumption	
Battery Recharge Duration	
Emergency Duration	
Protection Rating	
Insulation Class	
Operation Temperature	
LED Operating Life	
Battery Charge and Discharge Life Spa	
Outside Features	"Red" "
Test Button	
LED "On" Indicator	"Red "I
Testing Standard	



ATION

SLEL-05

Surface / Recess

Non-Maintained Type

2 x 1W High Quality LED chips

Powder-coated Mild Steel

AC 180V-242V, 50Hz

NiCd 12V 600mAh

2W

≤ 12 hours

≥ 3 Hours

IP20

Class one Earthing

 $0^{\circ}C{\sim}50^{\circ}C$


 $\geq 50000 \mbox{ Hours}$

Approx. 4 year

"Yellow" "Green" indication light & "Test" switch

Press type

"LED Mains On, "Green" LED Charging, "Yellow" LED Fault
HKFSD Codes of Practice for minimum service installations and equipments
*FSD PPA 104(A) 4th Revision
*BSEN 60598-2-22:2008, *BS 5266-1:2012



Web Site http:www.sl-led-application.com

E-mail

info@sl-led-application.com

Tel

852 - 2370 9394

Fax

852 - 2743 1123

Address

Unit 202A, 20/F., Tak King Industrial Building, 27 Cheung Lee Street, Chai Wan, Hong Kong.

Editor

Au Pui Man (openopw@gmail.com)